

2016 Remediation Final Report

(768 Total Outlets Sampled)

74 Exceeded the action level

1. Erwin Valley

| | | |
|----------|---------|---------------------|
| Room 105 | Bubbler | fixture changed out |
| Room 404 | Sink | fixture changed out |
| Room 103 | Sink | fixture changed out |
| Room 103 | Bubbler | fixture changed out |

1. Smith

| | | |
|----------|------------------|---------------------|
| Room 309 | Toilet room sink | filter installed |
| Room 120 | Sink | fixture changed out |

2. Carder

| | | |
|---------------|------------------|---------------------|
| Health Office | Toilet room sink | fixture changed out |
| Room 3 | Toilet room sink | fixture changed out |
| Room 59 | Bubbler | filter installed |
| Room 58 | Sink | fixture changed out |
| Room 56B | Toilet room sink | fixture changed out |
| Room 57B | Toilet room sink | fixture changed out |
| Room 32 | Toilet room sink | fixture changed out |
| Room 31 | Toilet room sink | fixture changed out |
| Room 52 | Sink | fixture changed out |

| | | |
|-----------|------------------|---------------------|
| Room 116B | Toilet room sink | fixture changed out |
| Room 111 | Sink | fixture changed out |
| Room 112 | Toilet room sink | fixture changed out |
| Room 229 | Sink | fixture changed out |
| Room 220 | Sink | fixture changed out |
| Room 220B | Toilet room sink | fixture changed out |
| Room 222 | Toilet room sink | fixture changed out |
| Room 224 | Bubbler | fixture changed out |
| Room 224 | Toilet room sink | fixture changed out |
| Room 226 | Toilet room sink | fixture changed out |
| Room 229 | Sink | fixture changed out |

1. Winfield

| | | |
|---------------|--------------------|---------------------|
| Kitchen | Deep Sink | fixture changed out |
| Health Office | Sink | fixture changed out |
| Room 100 | Toilet room sink | fixture changed out |
| Room 108 | Toilet room sink | filter installed |
| Room 202 | Toilet room sink A | fixture changed out |
| Room 202 | Toilet room sink B | fixture changed out |
| Room 208 | Sink | fixture changed out |
| Room 206 | Sink | fixture changed out |

1. Middle School

| | | |
|---|--------------------|---------------------|
| Kitchen | Sink 8 | filter installed |
| Boy's locker room | Toilet room sink 1 | fixture changed out |
| Room D-145 | Sink number 2 | fixture changed out |
| Staff Women's room | Toilet room sink 4 | fixture changed out |
| Room A-105 | Sink | fixture changed out |
| Pool fountain | Spigot | filter installed |
| Boy's locker room (pool) | Toilet room sink 1 | fixture changed out |
| Boy's gang toilet room Located across from B-116 | Toilet room sink 4 | fixture changed out |

2. High School

| | | |
|--------------------------|-----------------------------------|---------------------|
| Stadium | Women's toilet room (West) Sink 2 | fixture changed out |
| Kitchen | Sink 2 | fixture changed out |
| Kitchen | Sink 6 | fixture changed out |
| A-113 | Sink 1 | fixture changed out |
| B-114 | Sink 1 | fixture changed out |
| B-114 | Sink 2 | fixture changed out |
| Boy's locker room (pool) | Sink 1 | fixture changed out |
| Library | Sink 1 | fixture changed out |
| B211 | Sink 3 | fixture changed out |
| B211 | Sink 8 | fixture changed out |
| A207 | Sink | fixture changed out |
| D218 Prep room | refrigerator(IM) | filter installed |
| E208 | Fountain | fixture changed out |

| | | |
|-------------------------|--------------------------|--|
| E207 | Toilet room sink | fixture changed out |
| 3. <u>Severn</u> | | |
| Room 2B | Toilet room sink | fixture changed out |
| Room 110 | Toilet room sink | fixture changed out |
| Room 104 | Toilet room sink | fixture changed out |
| Room 103 | Toilet room sink | fixture changed out |
| Room 220 | Sink | fixture changed out |
| Room 226 | Toilet room sink | fixture changed out |
| Room 225 | Toilet room sink | fixture changed out |
| Room 119 | Sink | filter installed |
| Room 4B | Sink | fixture changed out |
| 4. <u>BOE</u> | | |
| Business Services | Sink | filter installed |
| 5. <u>Gregg</u> | | |
| Kitchen | Toilet room sink | filter installed |
| Room 111 | Bubbler | fixture changed out |
| Room 115 | Sink | fixture changed out |
| Room 114 | Sink | fixture changed out |
| Room 112 | Sink | fixture changed out |
| Library Room 102 | Sink Toilet room sink | fixture changed out fixture changed out |
| Room 101 | Sink | fixture changed out |

Room 101

Bubbler

fixture changed out